



NOTE:
 INSTALLATION OF ASSE 1024 DUAL CHECK VALVE (BACKFLOW PREVENTOR) IS REQUIRED BY WSSC FOR ALL WATER FOUNTAINS. WSSC WILL NOT INSTALL A WATER METER UNLESS THIS DEVICE HAS BEEN INSTALLED.

THE MARYLAND-NATIONAL CAPITAL PARK AND PLANNING COMMISSION
 Department of Parks, Montgomery County, Maryland

PARK DEVELOPMENT DIVISION
 9500 BRUNETT AVENUE
 SILVER SPRING, MD 20901

M. Pedocern
 CHIEF PARK DEVELOPMENT DIVISION
 12/17/2010
 DATE APPROVED

WATER FOUNTAIN DETAIL

REVISION	DATE	STANDARD No.
BSL	DEC 2010	511
		DEC 2010